

SECTION 23 52 16.13 SAMPLE SPECIFICATION FOR STAINLESS-STEEL CONDENSING BOILERS

PATTERSON-KELLEY, LLC SOLISTM CONDENSING BOILERS W/ NURO CONTROL

Part 1 - GENERAL

1.01 RELATED DOCUMENTS

ANSI Z21.13 / CSA 4.9 (Gas Fired Low Pressure Steam and Hot Water Boilers)

ASME Section IV (H Stamp Heating Boilers)

ASME CSD-1 (Controls and Safety Devices)

NBIC - Part 1 (Installation)

NFPA 54/ANSI Z221.3 (National Fuel Gas Code)

NFPA 70 (National Electric Code)

1.02 SUMMARY

A. This section includes gas-fired, high efficiency condensing hot water boilers with Stainless Steel heat exchangers.

B. Related Sections include, but are not limited to, the following:

Section 03 30 00 Cast-in-Place Concrete

Section 23 01 00 Operation and Maintenance of HVAC Systems

Section 23 05 16 Expansion Fittings and Loops for HVAC Piping

Section 23 05 19 Meters and Gages for HVAC Piping

Section 23 05 23 General-Duty Valves for HVAC Piping

Section 23 05 29 Hangers and Supports for HVAC Piping and Equipment

Section 23 05 48 Vibration and Seismic Controls for HVAC Piping...

Section 23 05 53 Identification for HVAC Piping and Equipment

Section 23 07 19 HVAC Piping Insulation

Section 23 09 13 Instrumentation and Control Devices for HVAC

Section 23 11 23 Facility Natural-Gas Piping

Section 23 11 26 Facility Liquefied-Petroleum Gas Piping

Section 23 21 00 Hydronic Piping and Pumps

Section 23 25 13 Water Treatment for Closed-Loop Hydronic Systems

Section 23 37 00 Air Outlets and Inlets

Section 23 51 00 Breechings, Chimneys, and Stacks

Section 23 53 00 Heating Boiler Feedwater Equipment

1.03 SUBMITTALS

The contractor must submit, in a timely manner, all submittals for approval to the engineer. Under no circumstances will the contractor install any materials until the engineer has made final approval on the submittals.

Product data and/or drawings must be submitted to the engineer for approval and must consist of:

General assembly drawing of the boiler including product description, model number, dimensions, clearances, weights, service sizes, etc.

Schematic flow diagram of the boilers gas valve train(s).

Schematic wiring diagram of the boilers control system that shows all components, interlocks, etc. and must clearly identify factory wiring and field wiring.

Full Function Factory Fire Test must be performed and documented on the boilers fire test label. A Factory Authorized Start-up must be completed prior to final acceptance by the engineer.

Operation and Maintenance Manuals must be submitted prior to final acceptance by the engineer and must contain shop drawings, product data, operating instructions, cleaning procedures, replacement parts list, maintenance and repair data, etc.

1.04 QUALITY ASSURANCE

The equipment must, at a minimum, be in strict compliance with the requirements of this specification, must perform as specified and must be the manufacturer's standard commercial product unless specified otherwise.

Electrically operated components specified are to be Listed and/or Labeled as defined by NFPA 70, Article 100.

Boiler must bear an ASME H stamp in accordance with ASME Section IV.

Boiler must be CSA certified to the ANSI Z21.13 / CSA 4.9 standard for Gas Fired Low Pressure Steam and

Hot Water Boilers and must bear an authorized CSA rating label.

Boiler must be AHRI listed and certified in accordance with the Commercial Boiler program and the BTS-2000 testing standard.

Boiler must undergo a Full Function Factory Fire Test and bear a fire test label.

Boiler must be registered through the National Board from the factory.

The manufacturer must make available, upon request, all quality assurance documentation and results of Full Function Factory Fire Test based on the boilers serial number.

1.05 COORDINATION

Equipment must be handled, stored and installed in accordance with the manufacturers instructions.

Factory Authorized Start-up must be completed after all appliance connections are completed, e.g. gas piping, hydronic piping, exhaust venting & electrical.

1.06 WARRANTY

The boiler manufacturer must warrant each boiler, including boiler, trim, boiler control system, and all related components, accessories, and appurtenances against defects in workmanship and material for a period of twelve (12) months from date of startup, provided that startup is completed within six (6) months of shipment and the start-up report is furnished to the manufacturer within thirty (30) days of startup.

The boiler manufacturer must warrant the boilers fuel burner for a period of five (5) years from date of startup, provided that startup is completed within six (6) months of shipment and the start-up report is furnished to the manufacturer within thirty (30) days of startup.

The boiler manufacturer must warrant the boilers heat exchanger for a period of ten (10) years from date of startup, provided that startup is completed within six (6) months of shipment and the start-up report is furnished to the manufacturer within thirty (30) days of startup.

The boiler manufacturer must also warrant the boilers heat exchanger against failure due to thermal shock for a period of ten (10) years from date of startup, provided that startup is completed within six (6) months of shipment and the start-up report is furnished to the manufacturer within thirty (30) days of startup.

1.07 CERTIFICATION

Manufacturers Certification - The boiler manufacturer must certify the following:

The products and systems furnished are in strict compliance with the specifications.

The boiler, burner and other associated mechanical and electrical equipment have all been properly coordinated and integrated to provide a complete and operable boiler.

The boiler must be in compliance with ANSI Z21.13 / CSA 4.9 (latest edition).

The boiler must be CSA certified for at least 97% efficiency based on operating conditions specified for testing under ANSI Z21.13 / CSA 4.9.

The boiler must be AHRI certified for at least 96% efficiency based on operating conditions specified for testing under BTS-2000.

The boiler must be in compliance with ASME Section IV (latest edition).

The boiler must be in compliance with ASME CSD-1 (latest edition).

The boilers H-3 form must be registered with the National Board.

Contractors Certification - The installing contractor must certify the following:

The products and systems installed are in strict compliance with the specifications and all applicable local and/or state codes.

The specified field tests have been satisfactorily performed by a factory authorized startup agent.

The equipment furnished contains inter-changeable parts with the specified equipment so that all major equipment parts can be obtained from the specified manufacturer.

Part 2 - Product

2.01 MANUFACTURERS

Furnish and install factory packaged low pressure hot water boiler(s) as manufactured by PattersonKelley, LLC or as approved and accepted by the Engineer as defined in the table below:

Each factory packaged boiler must be complete with all components and accessories necessary for a complete and operable boiler as hereinafter specified. Each boiler must be furnished factory assembled with the required wiring and piping as a selfcontained unit. Each boiler must be readily transported and ready for installation.

All Approved Equal or Approved Alternate boilers must demonstrate compliance with the requirements of this specification.

2.02 COMPONENTS

CABINET ENCLOSURE

Each boiler must feature a fully assembled cabinet enclosure fabricated from Carbon Steel or Aluminum sheet metal (minimum 16 Gauge) with powder coat finish.

The boilers cabinet enclosure must not exceed 35 in width and the completed boiler must fit through a standard double doorway.

The boilers cabinet enclosure must feature removable access panels / doors that can be easily opened.

The boilers cabinet enclosure must eliminate the use of refractory or other insulating materials by baffling the combustion air around the heat exchanger and the outer surface temperature must not exceed 20F above ambient temperature.

The boilers cabinet enclosure must prominently display all required safety, instruction, compliance and factory runout labels.

HEAT EXCHANGER

Each fire-tube boiler must contain an ASME Section IV heat exchanger with an H stamp designed for a maximum allowable working pressure of 160 PSIG and a maximum allowable temperature of 210F.

The completed heat exchanger must consist of welded 316L SS helical fired tubes and provide no less than the total fireside heating surface area defined in the table below:

Each completed heat exchanger must include an integral stainless-steel condensate pan/collector, condensate drain, removable burner assembly, inlet temperature sensor, outlet temperature sensor, flue gas temperature sensor, heat exchanger temperature sensor, automatic air vent, thermowell for high temperature limit capillary, low water cutoff probe or flow switch, and all necessary assembly hardware.

Each stainless-steel heat exchanger must be designed to maintain water turbulence at the full published range of acceptable flow rates at various boiler conditions as described below:

The maximum allowable flow rate will generate a 20F T when the boiler is operating at full capacity.

The minimum allowable flow rate will generate a 70F T when the boiler is operating at full capacity.

The boilers completed heat exchanger must be capable of operating with a minimum outlet water temperature of 42F.

Each heat exchanger must be hydrostatically tested by the manufacturer to a minimum of 1-1/2 times the maximum allowable working pressure for a minimum of 5 minutes. During this hydrostatic pressure test, the operator will inspect the pressure gauge and visually verify there are no water leaks.

MAIN GAS TRAIN

Boilers configured for single fuel operation must be equipped with an integral main gas valve train capable of burning Natural Gas.

Each gas valve train must include at least the following:

One (1) upstream manual shutoff valve for field-connection.

One (1) combination Air-Gas ratio control and safety shutoff valve with dual solenoids (in-series) that can be independently energized for leak testing and integrated into a single body design. The combination gas valve must operate as a Zero Governor and control to a neutral gas pressure inside the gas valve.

One (1) low gas pressure switch (manual reset).

One (1) high gas pressure switch (manual reset).

Two (2) gas pressure test ports.

One (1) downstream manual shutoff valve.

Each gas train must be completely independent and include dedicated safety devices, shutoff valves, etc.

Each gas train must be individually identified by the manufacturer with labels and dedicated paint colors (Yellow = Natural Gas).

The main gas valve train(s) must be factory assembled, piped, and wired and allow for operation at full rated boiler capacity from 3.5 - 4.0 W.C. up to the maximum inlet gas pressure of 14.0 W.C.

If the supplied gas pressure exceeds 14 W.C., the contractor must supply a suitable intermediate gas pressure regulator of the lock-up type to reduce the gas pressure to acceptable levels.

POWER BURNER

The boiler manufacturer must furnish an integral power type fuel burner with each boiler. The complete power fuel burner assembly must consist of a gas burner, combustion air blower, main gas valve train, and ignition system. The burner manufacturer must fully coordinate the burner design with the boilers heat exchanger and the boiler control system in order to provide the required capacities, efficiencies, and

performance specified. Boilers shipped without a power burner and field-equipped with a 3rd party power burner are not acceptable.

Burner must be single burner, fully modulating, with dynamic air density compensation control.

The burner must incorporate fuel/air ratio control system to preserve exhaust oxygen levels as per boiler schedule, maintaining consistent flue dew point.

The system must be linkage-less without the use of electronic control loops and electronic oxygen sensors requiring calibration and renewal.

Low NOx burner must be certified by SCAQMD for NOx levels listed on schedule when O2 is corrected to 3%. No additional setup or adjustment, such as increasing excess air, will be necessary to achieve level listed

Each burner must be installed vertically inside the combustion chamber with combustion gases flowing downward through the heat exchanger. The burner must consist of a stainless steel flange and perforated stainless steel cylinder.

Each boiler must be equipped with direct spark ignition. Main flame must be monitored and controlled by a flame rod / ionization probe (rectification) system.

BOILER SAFETY and TRIM DEVICES

The boiler manufacturer must furnish and test the following safety and trim devices with each boiler:

Safety relief valve must be provided in compliance with the ASME code. Contractor is required to pipe the relief valve discharge piping to an acceptable drain.

Water pressure/temperature gauge.

Low Water / Flow cutoff.

Manual reset high limit water temperature controller.

Operating temperature control to control the sequential operation of the burner.

High and Low Gas Pressure switches.

Flame rod / ionization probe flame detection.

The boiler manufacturer must provide a CSD-1 form identifying each safety and trim device.

The boiler must be capable of interfacing with the following external safety devices:

Auxiliary Low Water Cutoff device.

Combustion Air Damper End Limit Switch.

Emergency Stop (E-Stop) switch.

External Safety Device w/ contact closure.

BOILER CONTROL SYSTEM

Each boiler must be provided with all necessary controls, all necessary programming sequences, and all safety interlocks. Each boiler control system must be properly interlocked with all safeties.

Each boiler must be provided with a Full Modulating firing control system whereby the firing rate is infinitely proportional at any firing rate between low fire and high fire as determined by the pulse width modulation input control signal. Both fuel input and air input must be sequenced in unison to the appropriate firing rate without the use of mechanical linkage.

The boilers control system must provide the minimum capabilities:

7 color touchscreen display with one or more USB ports.

Standard on-board Ethernet port for wired internet connectivity.

Parameter uploads and downloads via external USB flash drive.

Software updates via external USB flash drive.

Capture screen shots from the controls display by saving digital image files to external USB flash drive.

Local Representative Screen can be programmed to provide contact information for the local boiler manufacturers representative.

Programmable Relay Outputs for direct control of pumps, control valves, dampers and other auxiliary devices.

Multiple boiler cascade network up to 32 boilers without any external control panel. The installation of external sequencing control panels is not acceptable.

Automatic hybrid system control for multiple boiler cascade systems with both condensing and non-condensing boilers. This control logic prioritizes condensing boilers at low water temperatures and prioritizes non-condensing boilers at high water temperatures.

Auxiliary Boiler Relay for multiple boiler cascade systems which can be used to enable a 3rd party boiler

platform in the event the cascade system is unable to satisfy the heating load.

Programmable Boiler and System pump control with modulating capabilities for multiple boiler cascade systems installed in a Primary-Secondary piping arrangement.

Programmable Control Valve logic with modulating capabilities for multiple boiler cascade systems installed in a Primary-Only piping arrangement.

Programmable synchronization of exhaust fan timing to equal the real-time burner firing rate.

5 Pre-installed PID control speeds for system optimization in addition to a user-defined PID function capability.

Integration with external Building Management Systems (BMS) via MODBUS RTU protocol. NOTE: Optional Protocol Converter for communication via LONWORKS and BACnet must be available for purchase from the boiler manufacturer.

Hardwire integration with Building Management Systems (BMS) via 4-20mA analog control signal for temperature or firing rate control.

Intuitive Setup Wizards ask the user a series of questions and allow for step-by-step configuration of the boiler operation, control, and connectivity.

On-Screen error notifications with a comprehensive description of all alarm conditions and several troubleshooting steps.

Automatic flue gas temperature and outlet (supply) temperature compensation to prevent over-firing of the boiler equipment.

Automatic differential temperature compensation to prevent over-firing of the boiler equipment in a low flow condition.

Automatically adjust the temperature set point and shutdown the boiler based on the outdoor air temperature conditions.

Night Setback functionality via external point of closure (or BMS integration) for unique Occupied and Unoccupied temperature setpoint values. Setback feature will include the ability to schedule multiple adjustments within a 24-hour period for building optimization.

Boosted boiler operation resulting in a pre-determined, timed, increase in boiler temperature setting in an

unexpected occupied mode.

Maintain single temperature set point with a minimum outlet (supply) water temperature of 42F up to a maximum outlet (supply) water temperature of 194F.

On-Board DHW Priority capable of seamless transition between Comfort Heat (CH) and Domestic Hot Water (DHW) operation.

On-Board CH&DHW operation for simultaneous Comfort Heat (CH) and Domestic Hot Water (DHW) operation.

Alarm Relay Output to announce alarm conditions which require manual reset on master or any member boiler from a single boiler source.

Programmable Low Fire Delay to prevent excessive short-cycling of the boiler equipment.

Local Manual Operation.

The boiler control system must be capable of interfacing with the following external control devices:

Building Management System (MODBUS). NOTE: Optional Protocol Converter for communication via LONWORKS and BACnet must be available for purchase from the boiler manufacturer.

Domestic Hot Water Break-on-Rise Aquastat (Normally Closed).

Domestic Hot Water Tank Temperature Sensor (12k).

External Header Temperature Sensor (12k).

Outdoor Air Temperature Sensor (12k) both wired and wireless.

Part 3 - Execution

3.01 INSTALLATION

Installation must be performed by the contractor in accordance with the requirements of the applicable codes.

Contractor must review the boiler and installation for compliance with requirements and/or issues that may affect boiler performance. Installation should not proceed until unsatisfactory conditions have been corrected.

The contractor must mount the equipment as described below:

Install boilers on cast-in-place concrete equipment base in compliance with the requirements for equipment bases and foundation specified in Section 03 30 00 Cast-in-Place Concrete.

If required by the local code, install vibration isolation devices in compliance with Section 23 05 48 Vibration and Seismic Controls for HVAC Piping and Equipment.

The contractor must install gas-fired boilers in accordance with NFPA 54/ANSI Z223.1 (United States), or CAN/CSA B/149.1 (Canada).

The contractor must install gas-fired boilers in accordance with NBIC Part 1 (Installation), or another installation code having local jurisdiction.

The contractor must assemble and install any external boiler safety/trim devices.

The contractor must install any electrical devices furnished with the boiler, but not specified to be factory-mounted.

The contractor must install control wiring to field mounted electrical devices in accordance with the requirements of NFPA 70.

The contractor must install electrical (power) wiring to the boiler in accordance with the requirements of NFPA 70.

3.02 CONNECTIONS

GAS PIPING

Each boiler must be provided with all necessary gas connections. Refer to the boilers specification sheet or manual for connection sizes.

Install gas piping in accordance with NFPA 54/ANSI Z223.1 (United States), or CAN/CSA B/149.1 (Canada).

For boilers configured for Natural Gas, refer to the requirements of Section 23 11 23 Facility Natural-Gas Piping.

HYDRONIC PIPING

Each boiler must be provided with all necessary inlet (supply) and outlet (return) connections. Refer to the boilers specification sheet or manual for connection sizes.

Check manufacturers installation manual for clearance dimensions and install piping that will allow for service and ease of maintenance.

Install piping from equipment drain connection to nearest floor drain. Piping must be at least full size of connection and adhere to proper codes for neutralization.

The hydronic piping and related components must comply with the requirements of 23 21 00 Hydronic Piping and Pumps.

All meters and gages in the hydronic piping must comply with the requirements of Section 23 05 19 Meters and Gages for HVAC Piping.

All instrumentation and controls in the hydronic piping must comply with the requirements of Section 23 09 13 Instrumentation and Control Devices for HVAC.

All valves in the hydronic piping must comply with the requirements of Section 23 05 23 General-Duty Valves for HVAC Piping.

All expansion fittings must comply with the requirements of Section 23 05 16 Expansion Fittings and Loops for HVAC Piping.

Any pipe hangers or supports must comply with the requirements of Section 23 05 29 Hangers and Supports for HVAC Piping and Equipment.

Any vibration isolation devices on the hydronic piping must comply with the requirements of Section 23 05 48 Vibration and Seismic Controls for HVAC Piping and Equipment.

The feedwater piping must comply with the requirements of Section 23 53 00 Heating Boiler Feedwater Equipment.

The hydronic piping must be insulated in accordance with the requirements of Section 23 07 19 HVAC Piping Insulation.

After insulation, all hydronic piping must be identified in accordance with the requirements of Section 23 05 53 Identification for HVAC Piping and Equipment.

Any water treatment of the hydronic system must be in accordance with the boiler manufacturers requirements and/or Section 23 25 13 Water Treatment for Closed-Loop Hydronic Systems.

EXHAUST VENTING

The boilers must be dual certified as Category II or IV appliances and are capable of operating with slightly negative to slightly positive exhaust vent pressure, and the vent gas temperature is likely to cause condensate production in the vent.

Install the exhaust/flue venting system in accordance with NFPA 54/ANSI Z223.1 (United States), or

CAN/CSA B/149.1 (Canada) and per the manufacturers recommendations in the installation manual.

All exhaust venting components must comply with the requirements of Section 23 51 00 Breechings, Chimneys and Stacks.

AIR INLET

The boilers must be certified for Direct Vent / Sealed Combustion installations where the combustion air is supplied directly to the boiler through ductwork.

Install the air inlet system in accordance with NFPA 54/ANSI Z223.1 (United States), or CAN/CSA B/149.1 (Canada) and per the manufacturers recommendations in the installation manual.

All air inlet components must comply with the requirements of Section 23 37 00 Air Outlets and Inlets.

ELECTRICAL

Install an external disconnect and overload protection for each boiler in accordance with the requirements of NFPA 70.

The voltage requirements for each boiler must be configured for:

SL725/850: 120VAC, Single-Phase, 60Hz

The amperage requirements for each boiler is described in the table below: